



160098220691

防爆电气设备
Explosion-proof electrical apparatus



中国认可
检测
TESTING
CNAS L1016

防爆合格证

Conformity certificate of Explosion-proof

证书编号 SYEx17. 0759
Certificate No.

| | | | |
|----------------------------|------------------------------------|---------------------|----------|
| 制造商 Manufacturer | 人民电器集团防爆电器有限公司 | | |
| 地址 Address | 乐清市柳市镇智广工业区(人民电器集团有限公司内) | | |
| 生产企业 Factory | 人民电器集团防爆电器有限公司 | | |
| 地址 Address | 乐清市柳市镇智广工业区(人民电器集团有限公司内) | | |
| 产品名称 Name of product | 防爆断路器 | | |
| 型号规格 Type specification | BLK52 | AC380V/220V | 80A |
| 防爆标志 Ex-marking | Ex d IIB T6 Gb/Ex tD A21 IP65 T80℃ | | |
| 产品标准 Product standards | Q/RMD 117-2017 | 图样编号 Drawing No. | BLK52-00 |
| 备注 Note | 本产品额定电流 80A 以下使用。 | | |



经对上述产品图样及技术文件的审查和样品检验, 确认符合下列标准:

According to the above examination of product designs drawings and technical documents, and sample inspection, it has been confirmed that the following standards are met:

| | |
|------------------|------------------------------|
| GB 12476. 1-2013 | 可燃性粉尘环境用电气设备 第1部分: 通用要求 |
| GB 12476. 5-2013 | 可燃性粉尘环境用电气设备 第5部分: 外壳保护型“tD” |
| GB 3836. 1-2010 | 爆炸性环境 第1部分: 设备 通用要求 |
| GB 3836. 2-2010 | 爆炸性环境 第2部分: 由隔爆外壳“d”保护的的设备 |

批准
Approved by

发证日期
Date of issue

2017-11-02

证书有效期至
Valid date

2022-11-01

机械工业低压防爆电器产品质量监督检测中心

Machinery industry Product Quality Supervisory and Test
Center of Low-voltage Explosion-proof Electrical Product



地址 Address: 沈阳市于洪区巢湖街 10 号

电话 Tel: 024-25833213、25833649-8033、8037

证书查询网址 Query URL: www.fbdqhy.com

邮编 Postcode: 110141

传真 Fax: 024-25303261-8037

E-mail: sy_ex@sina.com

注: 本证书仅对与审查认可文件及检验样品一致的产品有效。Note: This certificate is valid only for products which are in agreement with the review and approval documents and samples.