



150008220691

防爆电气设备  
Explosion-proof electrical apparatus



中国认可  
检测  
TESTING  
CNAS L1016

# 防爆合格证

## Conformity certificate of Explosion-proof

证书编号  
Certificate No. SYEx17. 0757

制造商 Manufacturer	人民电器集团防爆电器有限公司		
地址 Address	乐清市柳市镇智广工业区（人民电器集团有限公司内）		
生产企业 Factory	人民电器集团防爆电器有限公司		
地址 Address	乐清市柳市镇智广工业区（人民电器集团有限公司内）		
产品名称 Name of product	隔爆型防爆转换开关		
型号规格 Type specification	BZZ51	AC380V/220V	60A
防爆标志 Ex-marking	Ex d e II C T6 Gb/Ex tD A21 IP66 T80℃		
产品标准 Product standards	Q/RMD 115-2017	图样编号 Drawing No.	BZZ51-000
备注 Note	可代表本产品额定电流 60A 以下使用条件。		



经对上述产品图样及技术文件的审查和样品检验，确认符合下列标准：

According to the above examination of product designs drawings and technical documents, and sample inspection, it has been confirmed that the following standards are met:

GB 12476.1-2013	可燃性粉尘环境用电气设备 第1部分：通用要求
GB 12476.5-2013	可燃性粉尘环境用电气设备 第5部分：外壳保护型“tD”
GB 3836.1-2010	爆炸性环境 第1部分：设备 通用要求
GB 3836.2-2010	爆炸性环境 第2部分：由隔爆外壳“d”保护的设
GB 3836.3-2010	爆炸性环境 第3部分：由增安型“e”保护的设

批准  
Approved by

发证日期  
Date of issue



证书有效期至  
Valid date

2022-12-28

机械工业低压防爆电器产品质量监督检测中心

Machinery industry Product Quality Supervisory and Test  
Center of Low-voltage Explosion-proof Electrical Product



地址 Address: 沈阳市于洪区巢湖街10号

电话 Tel: 024-25833213、25833649-8033、8037

证书查询网址 Query URL: www.fbdqhy.com

邮编 Postcode: 110141

传真 Fax: 024-25303261-8037

E-mail: sy\_ex@sina.com

注：本证书仅对与审查认可文件及检验样品一致的产品有效。Note: This certificate is valid only for products which are in agreement with the review and approval documents and samples.