



中国认可
国际互认
检测
TESTING
CNAS L1020



实验室名称：国家电器产品质量监督检验中心

Lab Name: China National Center for Quality Supervision
and Test of Electrical Apparatus Products

No 21XB0460-S

型式试验报告 Type Test Report

委托单位：江西变电设备有限公司

Client:

产品名称：华式箱变式变电站

Name of Product:

产品型号：YBH-40.5/0.69-6300

Product Type:

检验类别：型式试验

Test Category:

本实验室对出具的检验（试验）结果负责，未经实验室书面同意，
不得部分地复制本报告。

The laboratory is responsible for the inspection (Test) results. The report shall
not be reproduced except in full, written approval of the laboratory.

国家电器产品质量监督检验中心

检 验 报 告

№：21XB0460-S

共 64 页 第 01 页

委托单位	江西变电设备有限公司	检验类别	型式试验
生产单位	江西变电设备有限公司	到样日期	2021 年 07 月 10 日
产品名称	华式箱变式变电站	产品类型	YBH-40.5/0.69-6300
生产单位地址	江西省抚州市崇仁县工业园区	原编号或生产日期	BD210732
检验日期	2021 年 07 月 14 日至 2021 年 07 月 18 日	送样数量	1 台
检验项目	出厂试验 强制的型式试验（不包括辅助和控制回路的附加试验） 验证预装式变电站声级的试验 设计和外观检查 外绝缘空气间隙测量	检验依据	GB/T17467—2020 DL/T537—2018 委托书要求
检验结论	华式箱变式变电站（型号：YBH-40.5/0.69-6300）出厂试验、强制的型式试验（不包括辅助和控制回路的附加试验）、验证预装式变电站声级的试验、设计和外观检查、外绝缘空气间隙测量的试验结果符合检验依据标准和委托书要求，样品上述试验合格。 签发日期：2021 年 7 月 20 日 有效期八年 注：本结论仅对送试样负责。		
备注	/		

编制：王雪灵

校对：陈乾

审核：李松

批准：李明智