



Certificate of Approval

Certificate No.: SAA-140403-EA

Date of Issue: 7 April 2014

Certificate Holder: People Ele. Appliance Group Co., Ltd.
People Industry Zone, Liushi, Yueqing,
Zhejiang, 325604
P.R. China

Class Description: Residual Current Device
Product Description: Residual Current Operated Circuit Breaker (RCCB)

Brand Name:

The logo for the brand '8 PEOPLE', featuring a stylized number '8' inside a square, followed by the word 'PEOPLE' in a bold, sans-serif font.

Model No.:

PID-63

Markings:

$U_n=240V\sim(1P+N)$

$I_n=16, 25, 32, 40, 50, 63A$

$I_{\Delta n}=0.03, 0.1, 0.3A$

Type A and AC

$I_{nc}=I_{dc}=6000A$

AS/NZS 61008.1:2011

Standard:

Conditions:

Nil

Approval Mark: SAA-140403-EA or RCM

Date First Registered: 20 March 2014

Date of Expiry: 20 March 2019

A stylized signature in black ink, appearing to be 'D' followed by a flourish.

For and on Behalf of
SAA Approvals Pty Ltd

Reissued to correct Standard.

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



140403/1a