

SGS

Certificate No: ED/2008/40002C

## VERIFICATION OF LVD COMPLIANCE

SGS-TW Reference No. : ED/2008/40002C

Model No : RDX65LE-63, DZ47LE-32, DZ47LE-63, RDX2LE-100, RDX30LE

Product Name : Earth Leakage Circuit Breaker

Applicant : People Ele. Appliance Group Zhejiang Import and Export corp.

Address of Applicant : People Industry Zone, Liushi, Yueqing, Wenzhou, Zhejiang, China 325604

Manufacturer : People Ele. Appliance Group Co., Ltd

Address of Manufacturer : People Industry Zone, Liushi, Yueqing, Wenzhou, Zhejiang, China 325604

Report No. : SCC(08) 086-10-LVD

Date of Issue : June 02, 2008

Applicable Standards : EN 60947-1:2004

## Conclusion

Based upon a review of the Test Report, the apparatus is deemed to meet the requirements of the above standards and hence fulfill the requirements of:

## Low Voltage Directive 2006/95/EC

Note: This certificate is only valid for the equipment and configuration described, and in conjunction with the test data detailed above.

Authorized Signatory:

SGS TAIWAN LTD. Jason Lin Technical Manager

Copyright of this certificate is owned by SGS Taiwan Electronics & Communication Services and may not be reproduced other than in full and with the prior approval of the Manager of SGS Taiwan Electronics & Communication Services.

134, Wu Kung Road, Wu Ku Ind. Zone, Taipei, Taiwan .

his document in larged by the Company under its Deveral Conditions of Service printed overlant. Attention is stress to the limitation of shifting independing the anti-critical response defined therein.

or holder of this document is advised that information contained become reflects the Company's findings at the time of its interestion only at within the limits of Client's interestions, if any. The Company's sale responsibility is to its Client and this document does not account artists to a transaction from exercising all their rights and obligations under the transaction documents. Any exactlerized afterestion, the part of the content or appearance of this document is unlawful and effective may be proceeded to the fulfact extent of the loss.

SGSPAPER 07301246

